

BID ADDENDUM #1

April 22, 2013

**Educational Services Building Reroof Project
California State University Stanislaus
One University Circle, Turlock, CA 95382**

Bid / Project Number: 12-202

Bid Opening Date: April 30, 2013

Bid Opening Time: 2:00 p.m.

This Addendum forms a part of the contract documents and modifies the original bidding documents dated April 2013. Addenda shall be noted as received and acknowledged on the Bid Proposal Form when submitted as outlined in the Bid Package referenced above.

The following corrections, additions, deletions, and/or modifications to the above package, by this reference, shall be incorporated therein:

Add Documents To Bid Specifications:

1. Please incorporate the attached document, **Addendum #1** into Exhibit I, General Requirements.

END OF ADDENDUM #1



ADDEND. NO. 1

CSUStanislaus
Educational Services Building
Turlock, CA

EDUCATION SERVICES BUILDING

- 1.0 The existing “sleepers” shall remain.
- 2.0 Provide a Unit Price (per sheet of plywood) to remove and replace deteriorated, delaminated plywood. Mechanically attach to existing metal deck, using the current type of fastener and current fastening pattern. Plywood shall be ½”, Struc I, CDX, 5-ply.

END OF ADDEND. NO.1