

BID ADDENDUM #2

May 12, 2023

To:
Prospective Bidders/Planholders

**Cafeteria Walk-Ins Replacement Project
Project 23-414
California State University Stanislaus
One University Circle, Turlock, CA 95382**

This Addendum forms a part of the contract documents and modifies the original bidding documents. Addendum shall be noted as received and acknowledged on the Bid Proposal Form when submitted as outlined in the Bid Package referenced above.

The following corrections, additions, deletions, and/or modifications to the above package, by this reference, shall be incorporated therein:

Addition:

- Do the walk-in units provided have to be NSF certified?
 - Yes, all three walk-in units must be NSF certified.

End of Addenda No. 2