

# **BID ADDENDUM #1**

**February 17, 2020**

To:  
**Prospective Bidders/Planholders**

**CENTRAL PLANT TRANSFORMER REPLACEMENT  
PROJECT #13041  
California State University Stanislaus  
One University Circle, Turlock, CA 95382**

**Bid / Project Number: ..... 13041**  
**Bid Opening Date: ..... February 20, 2020**  
**Bid Opening Time: ..... 2:00 p.m.**

This Addendum forms a part of the contract documents and modifies the original bidding documents. Addendum shall be noted as received and acknowledged on the Bid Proposal Form when submitted as outlined in the Bid Package referenced above.

The following corrections, additions, deletions, and/or modifications to the above package, by this reference, shall be incorporated therein:

**Modifications/Clarifications:**

1. Section 01 11 00: Revise paragraph 1.01.C to read:
  1. Reconnect existing primary and secondary feeders in kind; splice existing secondary conductors as maybe required onto new distribution.
  2. (Deleted)
2. Section 01 11 00: Revise paragraph 1.04.B to read; the outage may extend for more than 24 hours as stated within this document. However, the outage shall not extend longer than the calendar start and stop dates provided within this Document.
3. Section 26 12 00: Revise section title to read “SUBSTATION STYLE TRANSFORMERS” and not “DISTRIBUTION LIQUID FILLED TRANSFORMERS”.

End of Addenda No. 1