

BID ADDENDUM #2

March 24, 2020

To:

Prospective Bidders/Planholders

**PARKING LOT #11 RECONSTRUCTION PROJECT #13143
California State University Stanislaus
One University Circle, Turlock, CA 95382**

Bid / Project Number: 13143

Bid Opening Date: April 2, 2020

Bid Opening Time: 2:00 p.m.

This Addendum forms a part of the contract documents and modifies the original bidding documents. Addendum shall be noted as received and acknowledged on the Bid Proposal Form when submitted as outlined in the Bid Package referenced above.

The following corrections, additions, deletions, and/or modifications to the above package, by this reference, shall be incorporated therein:

Correction:

- 1) Sheet E2.0, Schedule: Revise Type 'B' and 'B1' part numbers to read Eaton #ARCH-M-AF48-80-D-8-T3
- 2) Sheet E3.0, Schedule: Revise Type 'B' and 'B1' part numbers to read Eaton #ARCH-M-AF48-80-D-8-T3

Questions and Answers:

- 1) The Lighting fixture schedule states catalog number ARCH-M-AF-48-80-D-U-T3 for Label A, but the wattage is listed as **166**. However, the catalog states 83 watts consistent with Label B and B1. Can you clarify if the 166 watts should be for AF48-**160**, projected at 18,982 lumens?

The wattage of 166 is for 2x83W heads on a single uni/pole.

- 2) The Addendum for sheet **E2** lists label A fixtures at 480V, but **E3** lists these fixtures as Universal (120-277V). Can you clarify the voltage?

Sheet E2.0, Schedule: Revise Type 'B' and 'B1' part numbers to read Eaton #ARCH-M-AF48-80-D-8-T3 to provide a 480V driver and not an universal driver as shown.

End of Addenda No. 2